

GENERAL NOTES & SPECIFICATIONS

- ALL DIMENSIONS UNLESS OTHERWISE STATED ARE IN FEET.
 - MISSING AND AMBIGUOUS DIMENSIONS IN ANY DRAWING ARE TO BE CLARIFIED FROM AUTHORITY CONCERNED.
 - DO NOT SCALE DRAWING, FOLLOW ONLY WRITTEN DIMENSIONS.
- R.C.C
- GENERAL GRADE OF REINFORCED CONCRETE M-20(NOMINAL) & OF P.C.C IS M-10 UNLESS OTHERWISE STATED, WITH W/C RATIO OF 0.50.
 - CEMENT:
 - USE 53 GRADE O.P.C CONFIRMING TO IS-2269
 - USE 43 GRADE O.P.C CONFIRMING TO IS-8112
 - COARSE AGGREGATE:
 - FREE FROM DELETERIOUS MATERIAL -B.T. METAL M.S.A = 20MM & DOWN FOR FOUNDATION, BEAM & COLUMNS 12.5 MM & DOWN FOR SLAB & SUCH THIN SECTION.
 - REINFORCEMENT: HYSD BARS OF GRADE Fe 500 CONFIRMING TO IS- 1786-1985.
 - * WELDING OF BARS WITH PERMISSION OF STRUCTURAL ENGINEER
 - * DEVELOPMENT/LAPPING LENGTH OF BARS (C=500 AND T= 550)
 - * MINIMUM CLEAR COVER TOR/F(OUTERMOST) FOUNDATION - 50 MM(SIDES, BOTTOM &TOP) COLUMN - 25.35 MM (SIDES) SLAB - 15 MM (SIDES) 25MM(BOTTOM &TOP) BEAM - 25 MM (TOP & BOTTOM)
 - CURING PERIOD FOR RCC - 14DAYS
 - STRIPPING TIME OF FORM WORK FOR RCC - AS DECIDED BY SITE ENGINEER IN ACCORDANCE WITH IS-456/2000.
 - REINFORCEMENT ALL THE CONCRETE ELEMENTS SHOULD BE GOT APPROVED BEFORE CASTING.
 - ANY DISCREPANCY IN FIELD DIMENSION SHOULD BE GOT CLARIFIED FROM THE CONSULTANTS.
 - PLEASE CHECK THE DIMENSION WITH RESPECT TO ARCHITECTURAL PLANS BEFORE EXECUTION.
 - FOR OTHER GENERAL DETAILS FOLLOW IS-456/2000 OR SEEK CLARIFICATION FROM CONSULTANTS.
 - THE BUILDING FOUNDATION IS DESIGNED FOR P+4 FLOOR ONLY.
 - THE EXCAVATED AREA OF PLINTH /FOUNDATION TO BE REFILLED WITH MURRUM /GOOD ENGINEERING EARTH.
 - COMPACT THE MURRUM TO GIVE A FIELD DENSITY OF 60-62 KG/CFT(2.3 GM/CC).
- NOTE:** ALL DRAWINGS ARE BEING REPAIRED BY OTHER DWG FOR FOUNDATIONS MUST BE BY SITE CONSULTANT, INCLUDING OTHER CONSULTANTS, SUPPLIERS, MANUFACTURERS BEFORE EXECUTION. ANY DISCREPANCY / AMBIGUITY TO BE BROUGHT TO ARCHITECTS NOTICE IN WRITING, REASONABLY IN ADVANCE. DONOT SCALE THE DRAWING, FOLLOW THE DIMENSIONS MENTIONED. ALL DIMENSIONS TO BE CHECKED AT SITE, DO NOT USE THE DRAWING FOR ANY OTHER PURPOSE THAN IT IS MEANT FOR.

REFERENCE DRAWINGS

DRAWING No.	TITLE	REV

STAMP

REV	DESCRIPTION	DATE	DWN	CHKD	APPD
	ISSUED FOR APPROVAL				

CLIENT
SMT:VIJAYALAKSHMI UPADYAYA

ARCHITECT:DEVIPRASAD KUNDESHWARA

DESIGN CONSULTANT: AAGAMAA DESIGNERS

MAIN CONTRACTOR

PROJECT TITLE
PROPOSED RESIDENCE BUILDING AT KRKALA

DRAWING FOR CONSTRUCTION

DRAWING TITLE
LINTEL DRAWING PLAN

THIS IS A CAD DRAWING AND MUST NOT BE ALTERED MANUALLY

DRAWING NUMBER: ORIG. DWG SIZE: A3 REV

