	ESTIMATE FOR ELECTRICAL WORKS AT: BRANCH & ATM LOBBY AT CANARA BANK, GHITORNI, NEW DELHI				
S. NO.	DESCRIPTION OF ITEM	QTY	иом	RATE (Rs.) (Excl. GST)	AMOUNT (Rs.) (Excl. GST)
1	Making temporary connections and shifting of points all across the Branch and for workstations (Electrical, UPS and telephone) to enable smooth functioning of the branch during renovation all complete as per the instructions of Bank's Engineer/ Architect. Item to include supplying all wires, cables, conduits etc. for the same. Nothing extra shall be payable in this regard	1.00	Job		
2	SITC of 3 Nos. 200 Amp. Kit-kat Fuse unit along with 200 Amp. neutral link on wooden board of size 2'0" x 2'0" complete with connections complete in all respect to the satisfaction of Bank.		Set		
3	ELECTRICAL PANEL Design, manufacture, providing, storing & installing in position, effecting proper connection, testing and commissioning of panel made of 16 SWG, CRCA sheet steel. It shall be dust and vermin proof. It shall have compartmentalized construction with bus bar chambers, cable alley, cable glands plate etc. as required, duly painted from inside as well outside. It shall have the following: MAIN PANEL: 1 No.100 Amp. TPN, MCCB (25 KA breaking capacity), Bus bars 100 Amp., 3 phase, 4 strips, 415 volts, 50 Hz. copper busbars with	1.00	No.		
	Bus bars 100 Amp., 3 phase, 4 strips, 415 volts, 50 Hz. copper busbars with colour coded PVC heat shrinkable sleeves. There should be 2 sets of BUS BAR in such a way that AC load should not be connected to GENERATOR power. 100 Amp. Changeover Switch Instruments: Digital Multi function Meter of standard make for displaying Input Voltage, Ampere, Power factor, KWH used with CTs.				
	OUTGOING: 2 Nos. 32 Amp. TP MCB (For LDB, PDB, Branch UPS, Inverter and Spare Feeder) from Generator Powered Bus. 2 Nos. 63 Amp. TP, MCB (For AC DB and Spare Feeders) from Non-Generator Powered Bus. 4 Nos. 32 AMP DP MCB. 3 Nos (for Glow Sign board, Strong Room, and spare feeder) from Generator Powered Bus. The design of panel should be got approved by the Architect before manufacturing. Also, the provision for 1/2 spare outgoings should be considered for future expansion. The job shall be completed to the satisfaction of the Pools.				
4	UPS I/P, O/P AND DISTRIBUTION & INVERTER INPUT & DISTRIBUTION				
a.	SITC of 32/40 Amp. TP MCB in encloser Double Door complete (Branch and Inverter Incomers) complete in all respects as required.	2.00	Nos.		
b.	SITC of 20/32 AMP Modular plug & socket along with MCB & plug top complete as per requirement and satisfaction of Bank. (2 for Branch's UPS Input, 2 for Branch's UPS Output)		Nos.		
c.	SITC of 12 WAY SPN Double Door DB complete with 1 No. 40 AMP DP MCB as incomer and 12 NOS. 6-10 AMP SPMCB as outgoing for Branch UPS power distribution to Computer points on Staff Counters / Tables.		No.		
d.	SITC of 8 WAY SPN Double Door DB complete with 1 No. 32 AMP DP MCB as incomer and 6 NOS. 6-10 AMP SPMCB as outgoing for UPS power distribution points for ESSENTIAL LOADS like CCTV System, Fire & Burglar Alarm Systems, Networking Rack, ATM and select Light points powered by UPS. Three way LED indicator lamps to be included with DB for power load, AC load adn UPS load to be located in front of CCTV camera.	1.00	No.		
f.	SITC of 40/63 Amp. Rotary Phase selector switch complete with RYB indication in enclosure for Branch's UPS input power network and Inverter. Complete in all respect as required.		No		
5	RAW POWER & FAN, LIGHTING DB & AC DISTRIBUTION BOARD				
a.	SITC of 4 WAY HTPN DB IP43,lko9, complete with 1 No. 63 AMP TP MCB as incomer and 12 NOS. 6-32 AMP. SPMCB for out going as LDB, complete in all respect as required.		Nos.		

b. incomer and 18 NOSI,18/20 AMP, SPMCB for out going as PDB & AC DB b. incomer and 18 NOSI,18/20 AMP, SPMCB for out going as PDB & AC DB complete in all respect as required. 6 CABLES All cables / wires shall be routed through PVC conduits / bends / elbows etc., as required, of appropriate dia. The conduits shall be clamped firmly to the walls / columns / pillars etc. with clips / clamps and fasteners rigidity even if above false ceiling. Complete job shall include cutting chiseling in walls, floor and making good of all chases / cuts etc. with combination of cement-mortar, including painting with type and shade of existing wall. The work shall be completed to the satisfaction of Bank. NO CABLE / WIRE / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL / CUSTOMER LOBBY / STATE WORKING AREA. a. SITC of 3.5 Core 5.0.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. b. SITC of 3.5 Core 5.0.5 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. 5.ITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x.6.0-1x.2.5 sqmm wiring mentioned below and not with 4 core 6.0.5 sq.mm Cable. 5.ITC of 2 cuns of 6.0.5 sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated d. Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards SITC of 4 core 10.0.5 sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of 3 core for 5 sq. as Sq. as a sq		Nos.	1.00	b. incomer and 18 NOS.18/20 AMP. SPMCB for out going as PDB & AC DB
complete in all respect as required. 6 CABLES All cables / wires shall be routed through PVC conduits / bends / elbows etc., as required, of appropriate dia. The conduits shall be clamped firmly to the walls / columns / pillars etc. with clips / clamps and fasteners rididly even if above false ceilina. Complete job shall include cutting chiseling in walls, floor and making good of all chases / cuts etc. with combination of cement-mortar, including painting with type and shade of existing wall. The work shall be completed to the satisfaction of Bank. NO CABLE / WIRE / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL / CUSTOMER LOBBY / STAFE WORKING AREA SITC of 3.5 Core 50.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. 5ITC of 3.5 Core 50.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. 5ITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panet to (a) LDB c) (b) PDB c) (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0-1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm clable SITC of 2 cuns of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated d. Multistrand Copper conductor wire from selector switch to LUPS to LUPS Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of 3 Lord Sq. Mm and 1 no. of 2.5 Sqmm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. 9 Multistrand Copper conductor wire from selector switch to inverter 1 SITC of 2C vs.1 Sqmm copper earth wire from 6 way DB to network rack. CCTV Fire alarm etc 1 SITC of 2C vs.1 Sqmm copper earth wire from 8 way LED indicator 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No		1403.	1.00	
All cables / wires shall be routed through PVC conduits / bends / elbows etc., as required, of appropriate dia. The conduits shall be clamped firmly to the walls / columns / pillars etc. with clips / clamps and fasteners rioidly even if above false cellino. Complete job shall include cutting chiseling in walls, floor and making good of all chases / cuts etc. with combination of cement-mortar, including painiting with type and shade of existing wall. The work shall be completed to the satisfaction of Bank. NO CABLE / WIRE / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL / CUSTOMER LOBBY / STAFE WORKING AREA. a. Iline connection up to Kit kat fuse unit complete in all respect as required. b. Iline connection up to Kit kat fuse unit complete in all respect as required. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB c. (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq. mm cable. SITC of 2 cuns of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated d. Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main e. Panel / Non Generator power Bus to (a) AC DB (b) Inverter. SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor wire from selector switch to inverter in Conductor FR Pvc/ Alpe insulated Wire in required dia pvc conduit complete in all respects as required. 9 MICT of 2 van so flo.0 Sq.mm and 1 no. of 2.5 Sq.mm RILS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter in all respects as required. 9 MICT of 20 x 2.5 Sqmm copper earth wire from 6 way DB to				[complete in all respect as required.
All cables / wires shall be routed through PVC conduits / bends / elbows etc., as required, of appropriate dia. The conduits shall be clamped firmly to the walls / columns / pillars etc. with clips / clamps and fasteners rigidly even if above false ceilling. Complete job shall include cutting chiseling in walls, floor and making good of all chases / cuts etc. with combination of cement-mortar, including painting with type and shade of existing wall. The work shall be completed to the satisfaction of Bank. NO CABLE / WIRE / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL / CUSTOMER LOBRY / STAFE WORKING AREA. SITC of 3.5 Core 50.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB c. (b) PDB c. (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm Cable. SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm RRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS 35.00 Mtr. Distribution boards. SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of 5 Sub main Wiring for Strong room, Single Phase AC and Glow Sign Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of 5 Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 no. of 2.5 Sqmm RRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete as 8.000 Mtr. SITC of 2 vurs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm RRLS PVC Insulated Multistrand Copper wir				6 CARLES
etc., as required, of appropriate dia. The conduits shall be clamped firmly to the walls / columns / pillars etc. with clips / clamps and fasteners rigidly even if above false ceiling. Complete job shall include cutting chiseling in walls, floor and making good of all chases / cuts etc. with combination of cement-mortar, including painiting with type and shade of existing wall. The work shall be completed to the satisfaction of Bank. NO CABLE / WIRE / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL / CUSTOMER LORBY / STAFF WORKING AREA. a. Inconnection up to Kit kat fuse unit complete in all respect as required. b. Iline connection up to Kit kat fuse unit complete in all respect as required. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core for 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated d. Multistrand Copper conductor wire from selector switch to UPS to UPS 35.00 Mtr. Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign f Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor RP xv/ xy be insulated Wire in required dia pvc conduit complete in all respects as required. SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter h SITC of 2 C x 2.6 Sqmm copper earth wire from 6 way DB to network rack . CCTV Fire alarm etc. I SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sqmm and 1 No. 2.5 Sqmm and 1 No. 2.5 Sqmm and 1 No. 2.5 S				
to the walls / columns / pillars etc. with clips / clamps and fasteners rigidity even if above false ceilling. Complete job shall include cutting chiseling in walls, floor and making good of all chases / cuts etc. with combination of cement-mortar, including painting with type and shade of existing wall. The work shall be completed to the satisfaction of Bank. NO CABLE / WIRE / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL / CUSTOMER LOBBY / STAFF WORKING AREA. SITC of 3.5 Core 50.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4. core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm Cable. SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated d. Multistrand Copper conductor wire from selector switch to UPS to UPS 35.00 Mtr. Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign f Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor R pvc/ sple insulated Wire in required dia pvc conduit complete in all respects as required. SITC of 2 cuts of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor from selectors witch to inverter h SITC of 2 cuts of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor from selectors witch to inverter h SITC of 2 Cx 1 Sq mm copper wire from selectors witch to inverter h SITC of 2 Cx 2.5 Sqnm copper earth wire from 8 way DB to network rack . CCTV				
ricidity even if above false ceiling. Complete job shall include cutting chiseling in walls, floor and making good of all chases / cuts etc. with combination of cement-mortar, including painiting with type and shade of existing wall. The work shall be completed to the satisfaction of Bank. NO CABLE / WIRE / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL / CUSTOMER LOBBY / STAFE WORKING AREA. a. In connection up to Kit kat fuse unit complete in all respect as required. b. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB c. (b) PDB c. (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x.60.0 + 12.2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq. mm Cable. SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS 05ktribution boards SITC of 4 core 1.0.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of 5 ub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduct complete in all respects as required. 9 SITC of 2 vans of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm Multistrand Copper conductor wire from selector switch to inverter 1 SITC of 2 vans of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm followers rack. So.00 Mtr. North of 2 vans of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm followers rack. So.00 Mtr. SITC of 2 vans of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm followers rack. So.00 Mtr. SITC of 2 Cx 1 Sq.mm copper wire from main panel to 3 way LED indicator 35.00 Mtr. SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 A				
Complete job shall include cutting chiseling in walls, floor and making good of all chases / cuts etc. with combination of cement-mortar, including painiting with type and shade of existing wall. The work shall be completed to the satisfaction of Bank. NO CABLE / WIRE / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL / CUSTOMER LOBBY / STAFE WORKING AREA. a. SITC of 3.5 Core 50.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. b. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB c. (b) PDB c. (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core for sq. Sa. mm cable. SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated d. Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards. SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main e. (a) AC DB (b) Inverter SITC of 5 Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ kype insulated Wire in required dia pvc conduit complete in all respects as required. SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter SITC of 2 Cx 2 Sq sqmm copper wire from main panel to 3 way LED indicator 35.00 Mtr. The conductor FR pvc/ kype insulated Wire in required dia pvc conduit co				
good of all chases / cuts etc. with combination of cement-mortar, including painting with type and shade of existing wall. The work shall be completed to the satisfaction of Bank. NO CABLE / WIRE / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL / CUSTOMER LOBBY / STAFE WORKING AREA. a. SITC of 3.5 Core 50.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. b. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB c. (a) LDB c. (b) PDB c. (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sn. mm Cable. SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated d. Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ klpe insulated Wire in required dia pvc conduit complete in all respects as required. GITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter in SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter in SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper wire from main panel to 3 way LED indicator 35.00 Mtr. The Cort of the sq. main wire from main panel				
including painiting with type and shade of existing wall. The work shall be completed to the satisfaction of Bank. NO CABLE / Wire / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL / CUSTOMER LOBBY / STAFF WORKING AREA. a. SITC of 3.5 Core 30.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. b. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated d. Multistrand Copper conductor wire from selector switch to UPS to UPS 35.00 Mtr. (a) AC DB (b) Inverter SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of 5ub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. 9 SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in Multistrand Copper conductor wire from selector switch to inverter 5 SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor wire from Selector switch to inverter 5 SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor wire from Selector switch to inverter 5 SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor wire from Selector switch to inverter 5 SITC of 2 runs of 1				
NO CABLE / WIRE / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL / CUSTOMER LOBRY / STAFE WORKING AREA. a. SITC of 3.5 Core 50.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. b. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm Cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated d. Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of 5 Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR. Pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor FR. pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor Wire from selector switch to inverter h SITC of 2 x x 2 S Sq.mm copper earth wire from 6 way DB to network rack . 50.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SpMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall 5-pil the Split ACs)				including painiting with type and shade of existing wall. The work shall be
a. SITC of 3.5 Core 50.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. b. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm Cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS 35.00 Mtr. Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of 5 Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ kipe insulated Wire in required dia pvc conduit complete in all respects as required. SITC of 2 C x 2.5 Sqmm copper earth wire from 6 way DB to network rack . So.00 Mtr. SITC of 2 C x 2.5 Sqmm copper wire from main panel to 3 way LED indicator 35.00 Mtr. AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split Acs)				completed to the satisfaction of Bank.
a. SITC of 3.5 Core 50.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. b. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm Cable. SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards. SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter. SITC of 50 bm ain Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ klpe insulated Wire in required dia pvc conduit complete in all respects as required. g Multistrand Copper conductor wire from selector switch to inverter. h CCTV Fire alarm etc i SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack . 50.00 Mtr. AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				NO CABLE / WIRE / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL /
a. line connection up to Kit kat fuse unit complete in all respect as required. b. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB c. (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm Cable. SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards. SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter. SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ klpe insulated Wire in required dia pvc conduit complete in all respects as required. g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated all respects as required. g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter. h CCTV Fire alarm etc i SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack . 50.00 Mtr. SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor wire from main panel to 3 way LED indicator . 50.00 Mtr. AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				CUSTOMER LOBBY / STAFF WORKING AREA.
a. line connection up to Kit kat fuse unit complete in all respect as required. b. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB C. (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm cable. SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards. SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter. SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ klpe insulated Wire in required dia pvc conduit complete in all respects as required. g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated all respects as required. g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated SITC of 2C x 2.5 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated SITC of 2C x 2.5 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated SITC of 2C x 2.5 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated SITC of 2C x 2.5 Sq.mm copper earth wire from 6 way DB to network rack . SITC of 2C x 1Sq mm copper wire from main panel to 3 way LED indicator . AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				SITC of 3.5 Core 50.0 Sq.mm Aluminium conductor Armoured Cable for service
b. SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm Cable. SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated d. Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards. SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter. SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. Growth France of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter SITC of 2 C x 2.5 Sqmm copper earth wire from 6 way DB to network rack CCTV Fire alarm etc Growth France SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 35.00 Mtr. AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respects as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)		Mtr.	15.00	line connection up to Kit kat fuse unit complete in all respect as required.
b. line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm Cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated d. Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Submain Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter To SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm And 1 no. of 2.5 Sq.mm Sq. on Mtr. AC (Split and Cassette) POINT SITC of AC Point Wring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respects as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				
line connection up to Kit kat fuse unit complete in all respect as required. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter h CTV Fire alarm etc i SITC of 2C x 2.5 Sq.mm copper earth wire from 6 way DB to network rack , 50.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SpMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)		N 4++	15.00	SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service
Panel to (a) LDB (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sa mm Cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. g GITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack , 50.00 Mtr. i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 35.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Conductor Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)		IVIU.	13.00	line connection up to Kit kat fuse unit complete in all respect as required.
Panel to (a) LDB (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sa mm Cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. g GITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter h CCTV Fire alarm etc i SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack , 50.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main
c. (a) LDB (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sar mm Cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS 35.00 Mtr. SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. 9 Mitr. SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter Normal SiTC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack CCTV Fire alarm etc i SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				
c. (b) PDB (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq. mm Cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter i SITC of 2 c x 2.5 Sqmm copper earth wire from 6 way DB to network rack , CCTV Fire alarm etc i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SpMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				
C. (c) Branch UPS input power supply. Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Scn mm Cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. 9 SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter h SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack , CCTV Fire alarm etc i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 35.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)		N 44.	25.00	(h) PDB
Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sc mm Cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS 01stribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. 9 SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter 1 SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack , CCTV Fire alarm etc SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 3 SiTC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)		Mtr.	25.00	C. [* *
be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sr mm Cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter h CCTV Fire alarm etc i SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack, CCTV Fire alarm etc i SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				
SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter BITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack , CCTV Fire alarm etc SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				
d. Multistrand Copper conductor wire from selector switch to UPS to UPS 35.00 Mtr. Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter h SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack CCTV Fire alarm etc i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 35.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				6 0 Sq mm Cable
Distribution boards SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter g SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack , CCTV Fire alarm etc i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 35.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				
e. SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter h SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack, CCTV Fire alarm etc i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 35.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)		Mtr.	35.00	inational depper conductor time non-selector sinten to eve to eve
e. Panel / Non Generator power Bus to (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter h SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack CCTV Fire alarm etc i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 35.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				
(a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack, CCTV Fire alarm etc i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				
(b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter In SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack CCTV Fire alarm etc In SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)		Mtr.	35.00	e.
SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack, CCTV Fire alarm etc i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				
f Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter h SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack , CCTV Fire alarm etc i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 35.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				
conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required. SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack CCTV Fire alarm etc i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				Board with 2 No. 40 Samm and 1 No. 25 Samm Multistrand Conner
all respects as required. g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter h SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack, CCTV Fire alarm etc i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 35.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)		Mtr.	80.00	
g SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter h SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack, CCTV Fire alarm etc i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 35.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				
h SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack, CCTV Fire alarm etc i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 35.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)		N 4±	35.00	SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated
h SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack , CCTV Fire alarm etc i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 35.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)	 	ıvitr.	35.00	Multistrand Copper conductor wire from selector switch to inverter
i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator 35.00 Mtr. 7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)	 	Mtr.	50.00	SITC of 2C x 2.5 Sqmm copper earth wire from 6 way DB to network rack,
7 AC (Split and Cassette) POINT SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs) 6.00 Nos.				CCTV Fire alarm etc
a. SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)		Mtr.	35.00	i SITC of 2C x 1 Sq mm copper wire from main panel to 3 way LED indicator
a. SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)				
a. Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)	 			7 AC (Split and Cassette) POINT
SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)	 			SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm
SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs)		Nos	600	Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp.
		1403.	0.00	SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall
8 EARTHING				•
				8 EARTHING
Preparation and commissioning of earth pits with PIP technology GEL type				Preparation and commissioning of earth pits with PIP technology GEL type
a. 50mmdia 3000mm long earth electrod. (One Dedicated Earthing for ATM UPS, 1.00 Nos.		Nos.	1.00	a. 50mmdia 3000mm long earth electrod. (One Dedicated Earthing for ATM UPS,
Branch UPS and main panel				
SITC of Earthing conductor from earth terminal to load point with 6.0 sq mm				SITC of Farthing conductor from earth terminal to load point with 6.0 sq. mm
b. multstrand copper conductor FR pvc /XLPE insulated cable in required dia pvc 75.00 Mtr.		Mtr.	75.00	-
conduit complete in all respect as required.				
9 UPS POINT 12.00 Nos.		Nos.	12.00	9 UPS POINT
Supply & Installation of point wiring for UPS or stabilized power plug points	 			
on workstations / table for computers using 3 X1.5 Sq.mm copper conductor				
multi starnd FR PVC sheathed flexible wire including PVC conduite laid floor				
raceways/conduit and taken upto table top using PVC rigid or flexible conduits				
run within wooden/metal partitions. Each point consisting of 1 No. Phase				
Indication light,1 No.16A Switch ,1No, 16Amp and 2Nos 6A , 5/6 pin sockets				
, , ,	}			
& wired together forming one point. The earth wire of green color only.				& wired together forming one point. The earth wire of green color only.

10	DAW DOWER DOINT			
10	RAW POWER POINT			
	Same as serial no.1, but providing power point by using 2*4.00 sq.mm. PVC	l		
	insulated 1100 V grade copper conductor wire with independent 1*4.0 sq.mm			
	earth wire from D.B. to first point (Primary Point) and first to second point with			
	2*2.5 sq.mm. PVC insulated 1100 V grade copper conductor wire and 1*2.5			
	earth wire (Secondary Point). All wiring is to be provided in PVC conduit of			
	suitable size. Each power point (Primary or Secondary) must include providing	l		
	and fixing of a dual socket combination of 1 no. 16 Amp 6 –pin socket with	l		
		l		
	16 Amp. switch & 1 no. 6 Amp 5-pin socket with 6 Amp. switch. The	l		
	switches should be Modular type switch / socket / plate etc. complete			
	There shall be a maximum of 2 points per circuit			
	NOTE: The power point, complete as mentioned above, shall be placed on the			
		l		
	low ht. / full ht. partition above the tables / counters at a suitable place to			
	ensure convenient accessability for staff. Primary Point	6.00	Nos.	
		6.00		
	Secondary Point	0.00	Nos.	
11	LIGHT/FAN POINT			
⊢''	LIGHT/FAN POINT			
	Supply & Installation of concealed point wiring using 600v grade 1.5 Sq.mm			
	copper conductor PVC insulated wires (with proper R,Y,B color code) pulled			
	through heavy gauge PVC conduits laid concealed over false ceiling including			
	2 Nos. 2.5 sqmm circuit wires from the relevant DB and also including 2.5	l		
	sqmm green color copper earth wire and switch plate, switches, etc. as	l		
	approved by the Bank's Engineer/Architect.			
a.	One light points controlled by one 6 amp. Modular switch.	30.00	Nos.	
	Two light points controlled by one 6 amp. Modular switch.			
b.	(Cost shall include wiring of the first point from the switch board and then	25.00	Nos.	
	looping from the first point to the second point)			
	Ceiling Fan Point including the cost of 6A Switch along with 5 step electronic	2.00		
C.	fan regulator.	3.00	Nos.	
-				
d.	IWall Fan Point along with 6 AMP switch	1 7.00	I INOS.	l
	Wall Fan Point along with 6 AMP switch	7.00 3.00	Nos.	
d. e. f.	Exhaust Fan Point along with 6 AMP switch	3.00	Nos.	
e.				
e.	Exhaust Fan Point along with 6 AMP switch	3.00	Nos.	
e. f.	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING	3.00	Nos.	
e. f.	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations /	3.00	Nos.	
e. f.	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing	3.00	Nos.	
e. f.	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing	3.00	Nos.	
e. f.	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing	3.00	Nos.	
e. f.	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing	3.00 1.00	Nos.	
e. f.	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box	3.00 1.00	Nos.	
e. f.	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point.	3.00 1.00	Nos.	
e. f.	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of	3.00 1.00	Nos.	
e. f. 13	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor	3.00 1.00	Nos.	
e. f.	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing	3.00 1.00	Nos.	
e. f. 13	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the	3.00 1.00	Nos.	
e. f. 13	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required.	3.00 1.00	Nos.	
e. f. 13	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing & fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure.	3.00 1.00 6.00	Nos.	
e. f. 13	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored	3.00 1.00 6.00	Nos.	
e. f. 13 1.1	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing & fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure.	3.00 1.00 6.00	Nos. Nos. Nos.	
e. f. 13 1.1 1.2 a) b)	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone Cable	3.00 1.00 6.00	Nos. Nos. Nos.	
e. f. 13 1.1	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored	3.00 1.00 6.00	Nos. Nos. Nos.	
e. f. 13 1.1 1.2 a) b)	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted, colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone Cable FIXTURES	3.00 1.00 6.00	Nos. Nos. Nos.	
e. f. 13 1.1 1.2 a) b)	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone Cable FIXTURES Supplying, installation with hanging support , testing and commissioning of	3.00 1.00 6.00	Nos. Nos. Nos.	
e. f. 13 1.1 1.2 a) b)	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone Cable FIXTURES Supplying, installation with hanging support , testing and commissioning of following light fixtures with electronic Ballasts, Tubes, lamps, all fixing materials	3.00 1.00 6.00	Nos. Nos. Nos.	
e. f. 13 1.1 1.2 a) b)	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone Cable FIXTURES Supplying, installation with hanging support , testing and commissioning of following light fixtures with electronic Ballasts, Tubes, lamps, all fixing materials including connecting wires etc. all complete as per the directions of Engineer-	3.00 1.00 6.00	Nos. Nos. Nos.	
e. f. 13 1.1 1.2 a) b)	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone Cable FIXTURES Supplying, installation with hanging support , testing and commissioning of following light fixtures with electronic Ballasts, Tubes, lamps, all fixing materials including connecting wires etc. all complete as per the directions of Engineer-in-charge.(all Commercial LED Light Fixures should be covered with minimum 3	3.00 1.00 6.00	Nos. Nos. Nos.	
e. f. 13 1.1 1.2 a) b)	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone Cable FIXTURES Supplying, installation with hanging support , testing and commissioning of following light fixtures with electronic Ballasts, Tubes, lamps, all fixing materials including connecting wires etc. all complete as per the directions of Engineer-	3.00 1.00 6.00	Nos. Nos. Nos.	
e. f. 13 1.1 1.2 a) b) 14	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone Cable FIXTURES Supplying, installation with hanging support , testing and commissioning of following light fixtures with electronic Ballasts, Tubes, lamps, all fixing materials including connecting wires etc. all complete as per the directions of Engineer-in-charge.(all Commercial LED Light Fixures should be covered with minimum 3	3.00 1.00 6.00	Nos. Nos. Nos. Mtrs.	
e. f. 13 1.1 1.2 a) b)	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone Cable FIXTURES Supplying, installation with hanging support , testing and commissioning of following light fixtures with electronic Ballasts, Tubes, lamps, all fixing materials including connecting wires etc. all complete as per the directions of Engineer-in-charge.(all Commercial LED Light Fixures should be covered with minimum 3 Years onsite replacement warranty)	3.00 1.00 6.00	Nos. Nos. Nos.	
e. f. 13 1.1 1.2 a) b) 14	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone Cable FIXTURES Supplying, installation with hanging support , testing and commissioning of following light fixtures with electronic Ballasts, Tubes, lamps, all fixing materials including connecting wires etc. all complete as per the directions of Engineer-in-charge.(all Commercial LED Light Fixures should be covered with minimum 3 Years onsite replacement warranty) FULL GLOW 2X2 LED 36W Ultra slim Smart Panel complete with driver of make	3.00 1.00 6.00	Nos. Nos. Nos. Nos.	
e. f. 13 1.1 1.2 a) b) 14	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone Cable FIXTURES Supplying, installation with hanging support , testing and commissioning of following light fixtures with electronic Ballasts, Tubes, lamps, all fixing materials including connecting wires etc. all complete as per the directions of Engineer-in-charge.(all Commercial LED Light Fixures should be covered with minimum 3 Years onsite replacement warranty) FULL GLOW 2X2 LED 36W Ultra slim Smart Panel complete with driver of make As specified in tender document or approved by bank LED 18/20 watt Tube Light with all accessories.make As specified in tender	3.00 1.00 6.00	Nos. Nos. Nos. Mtrs.	
e. f. 13 1.1 1.2 a) b) 14	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone Cable FIXTURES Supplying, installation with hanging support , testing and commissioning of following light fixtures with electronic Ballasts, Tubes, lamps, all fixing materials including connecting with electronic Ballasts, Tubes, lamps, all fixing materials including connecting with electronic Ballasts, Tubes, lamps, all fixing materials including connecting LED Light Fixures should be covered with minimum 3 Years onsite replacement warranty) FULL GLOW 2X2 LED 36W Ultra slim Smart Panel complete with driver of make As specified in tender document or approved by bank	3.00 1.00 6.00 110.00 13.00 8.00	Nos. Nos. Nos. Nos.	
e. f. 13 1.1 1.2 a) b) 14	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone Cable FIXTURES Supplying, installation with hanging support , testing and commissioning of following light fixtures with electronic Ballasts, Tubes, lamps, all fixing materials including connecting wires etc. all complete as per the directions of Engineer-in-charge.(all Commercial LED Light Fixures should be covered with minimum 3 Years onsite replacement warranty) FULL GLOW 2X2 LED 36W Ultra slim Smart Panel complete with driver of make As specified in tender document or approved by bank LED 18/20 watt Tube Light with all accessories.make As specified in tender document or approved by ARCHITECT OR BANK supplying , fixing ,testing and commissioning of 15 W LED commercial type	3.00 1.00 6.00 110.00 13.00 8.00	Nos. Nos. Nos. Nos.	
e. f. 13 1.1 1.2 a) b) 14 a. b.	Exhaust Fan Point along with 6 AMP switch Call Bell Point VOICE NETWORKING Wiring for Telephone / Intercom System from Tag Block to workstations / Tables / counters / outlets with 2 pair Telephone cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for RJ11 socket with shutter, RJ11 outlet, faceplate and mounting box complete of modular type. This work includes providing PVC conduits in chases from the tag block to the individual point. Supplying, laying, effecting terminations, testing and commissioning of 0.51mm dia Cu. Conductor, twisted , colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing &fixing conduit pipe or cable tray as required from building tag block to the floor as required. Supplying & fixing 20 pair krone tag block with enclosure. P/L 20 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone Cable FIXTURES Supplying, installation with hanging support , testing and commissioning of following light fixtures with electronic Ballasts, Tubes, lamps, all fixing materials including connecting wires etc. all complete as per the directions of Engineer-in-charge.(all Commercial LED Light Fixures should be covered with minimum 3 Years onsite replacement warranty) FULL GLOW 2X2 LED 36W Ultra slim Smart Panel complete with driver of make As specified in tender document or approved by bank LED 18/20 watt Tube Light with all accessories.make As specified in tender document or approved by ARCHITECT OR BANK	3.00 1.00 6.00 110.00 13.00 8.00	Nos. Nos. Nos. Nos. Nos. Nos.	

Vall mounted fans 450 mm dia. make as specified in tender document or pproved by ARCHITECT OR BANK	7.00	Nos.		
upply &fixing of Ceiling fans 1200 mm double ball bearing make As specified n tender document or approved by ARCHITECT OR BANK with required down od and hanging arrangement		Nos.		
supply & fixing of 230 mm exhaust fan 'Ventilair DX W' with self closing buvers and plastic body with all accessories etc. complete of make As specified a tender document or approved by ARCHITECT OR BANK		Nos.		
ITC of Call Bell.	1.00	No.		
TOTAL FOR ELECTRICAL WORKS (EXCLUDING GST)				
Discount If any (Only on Excluding GST amount only)				
Net Amount (After Discount if any - Excluding GST) (Discount if any shall be given on Amount in Sub part (A -Excluding GST) Not on sub part (C)).				
GST as extra as applicable (For ELECTRICAL works) - By Bank				
	poproved by ARCHITECT OR BANK supply &fixing of Ceiling fans 1200 mm double ball bearing make As specified a tender document or approved by ARCHITECT OR BANK with required down and hanging arrangement supply & fixing of 230 mm exhaust fan 'Ventilair DX W' with self closing buvers and plastic body with all accessories etc. complete of make As specified a tender document or approved by ARCHITECT OR BANK ITC of Call Bell. TOTAL FOR ELECTRICAL WORKS (EXCLUDING GST) Discount If any (Only on Excluding GST amount only) Net Amount (After Discount if any - Excluding GST) (Discount if any on Amount in Sub part (A -Excluding GST) Not on sub part	poproved by ARCHITECT OR BANK upply &fixing of Ceiling fans 1200 mm double ball bearing make As specified a tender document or approved by ARCHITECT OR BANK with required down and and hanging arrangement upply & fixing of 230 mm exhaust fan 'Ventilair DX W' with self closing ouvers and plastic body with all accessories etc. complete of make As specified a tender document or approved by ARCHITECT OR BANK ITC of Call Bell. 1.00 TOTAL FOR ELECTRICAL WORKS (EXCLUDING GST) Discount If any (Only on Excluding GST amount only) Net Amount (After Discount if any - Excluding GST) (Discount if any shall be on Amount in Sub part (A -Excluding GST) Not on sub part (C)).	poproved by ARCHITECT OR BANK supply &fixing of Ceiling fans 1200 mm double ball bearing make As specified a tender document or approved by ARCHITECT OR BANK with required down and and hanging arrangement supply & fixing of 230 mm exhaust fan 'Ventilair DX W' with self closing suvers and plastic body with all accessories etc. complete of make As specified at tender document or approved by ARCHITECT OR BANK TOTAL FOR ELECTRICAL WORKS (EXCLUDING GST) Discount If any (Only on Excluding GST amount only) Net Amount (After Discount if any - Excluding GST) (Discount if any shall be given on Amount in Sub part (A -Excluding GST) Not on sub part (C)).	poproved by ARCHITECT OR BANK upply &fixing of Ceiling fans 1200 mm double ball bearing make As specified at tender document or approved by ARCHITECT OR BANK with required down and and hanging arrangement upply & fixing of 230 mm exhaust fan 'Ventilair DX W' with self closing buvers and plastic body with all accessories etc. complete of make As specified at tender document or approved by ARCHITECT OR BANK ITC of Call Bell. TOTAL FOR ELECTRICAL WORKS (EXCLUDING GST) Discount If any (Only on Excluding GST amount only) Net Amount (After Discount if any - Excluding GST) (Discount if any shall be given on Amount in Sub part (A -Excluding GST) Not on sub part (C)).