

Phone: 020 - 25530622; Email: pecopne@canarabank.com; Website: www.canarabank.com

	MEDICAL SQUARE BRANCH, DIST. NAGPUR				
S.	DESCRIPTION OF ITEM	UNIT	QTY	RATE (₹)	AMOUNT (₹)
NO.				(Excl. GST)	(Excl. GST)
	MAIN PANEL / DISTRIBUTION BOARDS / MCCBs:				
1.1.	MAIN INCOMER - 100A FP MCCB 16kA in Sheet steel Enclosure Box	Nos.	1.00		
	Supplying & Installing 100A, FP MCCB in IP65W Sheet Steel Enclosure complete, complete with Gland				
	Box, Cable managers, rubber / silicone sealing gasquets, locking arrangement etc.				
	The Box should be placed outside the premises at a suitable location preferably safe from rainfall				
	and accidental human contact.				
1 2	BUS-BAR: SIT of 100A 415V 4 strip Step Type Bus Bar chamber box complete with enclosure made out	Set	1,00		
	of powder coated CRCA having gland plates with conduit knockouts, earthing terminals. The	500			
	enclosure must have proper insulation and locking arrangement.				
	chetosare muse have proper insulation and toeking arrangement.				
1.3.	MAIN PANELS / DBs:				
	SITC sheet metal fabricated & powder coated Double Door Type MCB Distribution Boards				
	(surface/flush mounted). DB's shall have MCB/MCCB as incomer, RCCB as sub-incomer & SP/DP/TP				
	MCB as outgoing, complete with Per Phase Isolation. All MCBs of B/C characteristics (B type for Light				
	and Fan load and C type for rest of the load) and 10 KA breaking capacity. The ELCB's, RCCB's, RCBO's				
	should be of 100mA sensitivity. The DB shall have appropriate no. of top & bottom knock outs for				
	outgoing circuits & shall be complete with necessary bus bars, interconnecting terminals & earth				
	studs. All terminations in DB shall be complete with feruling, dressing with lugs & all circuits shall be				
	properly labeled with PVC strip (sticker type) having identification as per the final approval of the				
	Bank / Architect / Consultant.				
1.3.1.	VTPN DB1 - SITC Lighting, AC & Raw Power Main DB (Non-Essential Load)				
	4 way VTPN - MCCB DB,	Nos.	1.00		
	415V 63Amp. TPN, MCCB (16 KA breaking capacity)	Nos.	1.00		
	25 A - TP MCB outgoing (LDB)	Nos.	2.00		
	63 A - TP MCB outgoing (AC & PDB & Spare)	Nos.	2.00		
v)	Blanking plates	Nos.	2.00		
L					
	VTPN DB2 - SITC UPS, ATM & GSB Main DB (Essential Load)				
	4 way VTPN - MCCB DB,	Nos.	1.00		
	415V 63Amp. TPN, MCCB (16 KA breaking capacity)	Nos.	1.00		
111)	25/32 A - SP MCB outgoing (Branch UPS Input, Inverter Input, ATM UPS Input, ATM Lighting & AC DB,	Nos.	6.00		
ivi	Glow Sign Board, Spare Feeders) Blanking plates	Nos.	6.00		
17)	Did iking places	1105.	0.00		
-	DISTRIBUTION BOARDS				
	SITC sheet metal fabricated & powder coated Double Door Type MCB Distribution Boards				
	(surface/flush mounted). DB's shall have MCB/MCCB as incomer, RCCB as sub-incomer & SP/DP/TP				
	MCB as outgoing, complete with Per Phase Isolation. All MCBs of B/C characteristics (B type for Light				
	and Fan load and C type for rest of the load) and 10 KA breaking capacity. The ELCB's, RCCB's, RCBO's				
	should be of 100mA sensitivity. The DB shall have appropriate no. of top & bottom knock outs for				
	outgoing circuits & shall be complete with necessary bus bars, interconnecting terminals & earth				
	studs. All terminations in DB shall be complete with feruling, dressing with lugs & all circuits shall be				
	properly labeled with PVC strip (sticker type) having identification as per the final approval of the				
	Bank / Architect / Consultant.				
2.a	SITC LIGHTING DB1 (For Lighting of Non Banking Hall area)				
	4 way TPN - MCB DB,	Nos.	1.00		
	25 A - FP MCB, as incomer	Nos.	1.00		
	25 A - DP 30mA RCCB, as sub-incomer	Nos.	3.00		
	6/10 A - SP MCB outgoing (6A for Light & Points, 10 A for Sockets)	Nos.	6.00		
	Blanking plates	Nos.	0.00		

Seal-Sign of the Bidder



Phone: 020 - 25530622; Email: pecopne@canarabank.com; Website: www.canarabank.com

BOQ FOR ELECTRICAL WORKS IN BRANCH PREMISES & ATM LOBBY AT:

MEDICAL SQUARE BRANCH, DIST. NAGPUR					
S.	DESCRIPTION OF ITEM	UNIT	QTY	RATE (₹)	AMOUNT (₹)
NO.				(Excl. GST)	(Excl. GST)
2.a. ii	Reutilising the existing 4 Way TPN MCB DB by providing the mentioned items and making				
	interconnections as required for providing circuits				
	LIGHTING DB2				
	4 way TPN - MCB DB,	Nos.	0.00		
	25 A - FP MCB, as incomer	Nos.	0.00		
	25 A - DP 30mA RCCB, as sub-incomer	Nos.	3.00		
	6/10 A - SP MCB outgoing (6A for Light & Points, 10 A for Sockets)	Nos.	2.00		
vi)	Blanking plates	Nos.	2.00		
2.b	SITC RAW POWER & AC DB				
i)	6 way TPN - MCB DB,	Nos.	1.00		
ii)	63 A - TPN MCB	Nos.	1.00		
iii)	40 A - DP 100mA RCCB, as sub-incomer	Nos.	3.00		
	10/16/20/25/32 A - SP MCB outgoing	Nos.	12.00		
2.c	SITC Branch UPS Sub Main DB				
i)	6 way SPN - MCB DB,	Nos.	1.00		
	40 A - DP MCB as incomer	Nos.	1.00		
	40 A - DP 100mA RCCB, as sub-incomer	Nos.	1.00		
	20/32 A - SP MCB outgoing, 1 for UPS Output DB 1 &1 for UPS Output DB 2	Nos.	2.00		
,	and the second of the second o	.,,,,,			
2.d	SITC Branch UPS Output DB 1 (Essential Load) (Existing DB to be used)				
	8 way SPN - MCB DB,	Nos.	0.00		
	32 A - DP MCB as incomer	Nos.	0.00		
	6/10/16 A - SP MCB outgoing, 1 Point for CCTV, 1 Point for Data Network rack, 1 Point for Fire	Nos.	3.00		
,	Alarm System, 1 Point for Security alarm system, 1 for ATM & 1 No. Spare Feeder	1103.	3.00		
	Actum System, 11 ome for Security diamin system, 11 or Arm a 1100. Spare recuer				
2 0	SITC Branch UPS Output DB 2 (Non - Essential Load) (Existing DB to be used)				
	12 way SPN - MCB DB,	Nos.	0.00		
	32 A - DP MCB as incomer	Nos.	0.00		
	6/10/16 A - SP MCB outgoing, for Computer Power Points on Tables, Counters and Work Stations.	Nos.	4.00		
111)	10/10/16 A - 3P MCB outgoing, for computer Power Points on Tables, Counters and Work Stations.	NOS.	4.00		
2 f	SITC INVERTER Lighting DB				
	16 way SPN - MCB DB,	Nos.	1.00		
	25 A - DP MCB as incomer	Nos.	1.00		
	25 A - DP 30mA RCCB, as sub-incomer	Nos.	1.00		
	6/10A - SP MCB outgoing	Nos.	8.00		
14)	W. TON SI MICE OULSOINS	1103.	3.00		
2 ~	SITC ATM UPS Output DB				
	4 way SPN - MCB DB,	Nos	1.00		
	25 A - DP MCB as incomer	Nos.	1.00		
		Nos.			
111)	10/16A - SP MCB outgoing	Nos.	2.00		
n L	CITC ATM I GAC DD				
	SITC ATM L&AC DB	NI	4.00		
	6 way SPN - MCB DB,	Nos.	1.00		
	32 A - DP MCB as incomer	Nos.	1.00		
	6/20A - SP MCB outgoing	Nos.	3.00		
iv)	Blanking plates	Nos.	2.00		
	HER POYES				
3	MCB BOXES				<u> </u>

2



MEDICAL SQUARE BRANCH, DIST. NAGPUR					
S. NO.	DESCRIPTION OF ITEM	UNIT	QTY	RATE (₹) (Excl. GST)	AMOUNT (₹) (Excl. GST)
3.a.	SITC 2 way - MCB with Box,				
	for switching OFF Non-Essential Branch UPS output & Inverter Lighting Output (TO BE				
	LOCATED NEAR THE ENTRANCE OF BRANCH NEXT TO VTPN DBs)				
	Sheet steel Enclosure Box for DP MCB	Nos.	2.00		
ii)	32/20 A - DP MCB	Nos.	2.00		
3.b.	SITC 2 way - MCB with Box, for Branch UPS Input & Output, ATM UPS Input & Output, for Inverter				
	output				
	Sheet steel Enclosure Box for DP MCB	Nos.	3.00		
	32/25/20 A - DP MCB	Nos.	3.00		
3.b.ii	Existing DP MCB with enclosure to be dismantled, relocated and refixed for use	Nos.	2.00		
3.c.	SITC 4 way - MCB with Box, for Inverter Input				
i)	Sheet steel Enclosure Box for FP MCB	Nos.	1.00		
ii)	25 A - DP MCB	Nos.	1.00		
iii)	25 A - DP 30mA RCCB, as sub-incomer	Nos.	1.00		
3.d.	SITC 4 way - MCB with Box, for Glow Sign Board				
	Sheet steel Enclosure Box for FP MCB	Nos.	1.00		
ii)	25 A - DP MCB	Nos.	1.00		
	25 A - DP 30mA RCCB, as sub-incomer	Nos.	1.00		
4	AC POINTS - To be drawn from RAW POWER & AC DB (S.No. 2.b)				
	Supplying & Installing 20 A Power Socket points complete with MS concealed box, 20A Modular	Nos.	7.00		
	Socket, and 20/25A SPMCB with necessary screws, nylon plug, Saddles, hardware etc. The point				
	cost must be inclusive of 2x4.0 Sq.mm. + 1x2.5 Sq. mm. PVC insulated FRLS Multistrand copper				
	Conductor wires concealed inside 25mm/20 mm PVC conduit. (For High Wall Split AC Units)				
	NOTE: Provision should be made in the point wiring for insertion and installation of AC stabilizers				
	with proper terminations using lugs and sealants. The wiring from AC DB to stabilizers and from stabilizers to the actual end point must be concealed in PVC Conduits of appropriate dia.				
	STRONG ROOM WIRING	Mari	4.00		
5	STRONG ROOM WIRING	Nos.	1.00		
	Supplying & Installing 20 A Power Socket points complete MS concealed box, Modular Switch				
	plate, 20A Modular Socket, controlled by a Modular 20A SP MCB with necessary screws, nylon				
	plug, Saddles, hardware etc. including cost of 2x2.5.0 sqmm + 1x1.5 sqmm PVC insulated FRLS				
	copper Wires and 25mm/20 mm PVC conduit, For Strong Room / Cash room Entrance as It's				
	Lighting circuit control from outside. Lighting switch board inside the Strong room / Cash room to				
	be connected using, 2 Mtr. 3 core 1.5 sq mm flexible copper cable with a 15 A plug top from this				
	power socket installed outside the room (rate should be given inclusive of flexible cable, plug top, circuit and flexible conduit for the 2 Mtr. Link)				
6	CABLES & TERMINATIONS				
	Supply and Laying of following LT cables confirming to IS 1554 (part 1) with necessary M.S. clamps.				
	All such cables shall be provided with temporary labeling at every 20 mtr. & then finally with metal				
	identification tags showing the size & the location from/to the specific panel/DB; at both the ends.				
	The rate is inclusive of termination charges				
	The existing Wires and Cables to utilised along with new wires and cables. The existing submain wiring for UPS DBs and cabling to be kept as it is				
6.1	Copper Flexible Cables				



MEDICAL SQUARE BRANCH, DIST. NAGPUR					
S. NO.	DESCRIPTION OF ITEM	UNIT	QTY	RATE (₹) (Excl. GST)	AMOUNT (₹) (Excl. GST)
6.1.a.	2C x 4 Sq.mm. Copper Conductor Flexible Cable + 2.5 Sq. mm. PVC Insulated Multistrand Copper	Rmt	100.00		
	Conductor wire for earth,				
	1. From VTPN DB2 (S.No. 1.3.2.) to ATM UPS Input MC Box (S.No. 3.b.)				
	2. From ATM UPS Input MCB Box (S.No. 3.b.) to ATM UPS				
	3. From ATM UPS to ATM UPS Output MCB Box (S.No. 3.b.)				
	4. From ATM UPS Output MCB Box (S.No. 3.b.) to ATM Output DB (S.No. 2.g)				
	5. From VTPN DB2 (S.No. 1.3.2.) to ATM L&AC DB (S.No. 2.h.)				
	6. From VTPN DB2 (S.No. 1.3.2.) to Inverter Input MCB Box (S.No. 3.c.)				
	7. From Inverter Input MCB Box (S.No. 3.c.) to inverter				
	8. From Inverter to inverter output MC Box (S.No. 3.b.)				
	9. From VTPN DB2 (S.No. 1.3.2.) to GSB MCB Box (S.No. 3.d)				
	10. From GSB MCB Box (S.No. 3.d) to Glow Sign Board				
	11. From Branch UPS Sub Main DB SP MCB1 (S.No. 2.c.iv) to Branch UPS Output DBs 1 (S.No. 2.d)				
6.1.b.	2C x 6 Sq.mm. Copper Conductor Flexible Cable + 4.0 Sq. mm. PVC Insulated Multistrand Copper	Rmt	70.00		
	Conductor wire for earth,				
	1. From VTPN DB2 (S.No. 1.3.2.) to Branch UPS Input MCB Box (S.No. 3.b.)				
	2. From Branch UPS MCB Box (S.No. 3.b.) to Branch UPS				
	3. From Branch UPS to Branch UPS Output MCB Box (S.No. 3.b.)				
	4. From Branch UPS Output MCB Box SPMCB1 (S.No. 3.b.) to Branch UPS Sub Main DB (S.No. 2.c.)				
	5. From Branch UPS Sub Main DB SPMCB2 & neutral (S.No. 2.c.iv) to MCB Box (S.No. 3.a) at entrance				
	6. From MCB Box at entrance (S.No.3.a) to Input side of DP MB Incomer of Branch UPS Output DB 2 (S.No.				
	2.e.ii)				
6.1.c.	4C x 4 Sq.mm. Copper Conductor Flexible Cable + 2.5 Sq. mm. PVC Insulated Multistrand Copper	Rmt	50.00		
	Conductor wire for earth,				
	1. From VTPN DB1 to Lighting DB 1 (S.No. 2.a)				
	2. From VTPN DB1 to Lighting DB 2 (S.No. 2.a ii)				
6.1.d.	4C x 10 Sq.mm. Copper Conductor Flexible Cable + 6.0 Sq. mm. PVC Insulated Multistrand Copper	Rmt	20.00		
	Conductor wire for earth,				
	1. From VTPN DB to Raw Power & AC DB (S.No. 2.b)				
6.1.e.	3C x 2.5 Sq.mm. Copper Conductor flexible cable,	Rmt	80.00		
	1. From inverter output MCB Box (S.No. 3.b.) to MCB Box (S.No. 3.a) at entrance				
	2. From MCB Box (S.No. 3.a) at entrance to Input side of DP MCB Incomer of inverter lighting DB (S.No.				
	2.f.ii)				
	POINT WIRINGS				
	Complete job shall include cutting chiseling in walls, floor and making good of all chases / cuts				
	etc. with combination of cement-mortar, including painiting with type and shade of existing wall.				
	The work shall be completed to the satisfaction of Bank.				
	NO CABLE / WIRE / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL / CUSTOMER LOBBY / STAFF				
	WORKING AREA. (No seperate measurements for circuit wiring & PVC Conduits)				
	Complete job shall include cutting chiseling in walls, floor and making good of all chases / cuts				
	etc. with combination of cement-mortar, including painiting with type and shade of existing wall.				
	The work shall be completed to the satisfaction of Bank.				
	NO CABLE / WIRE / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL / CUSTOMER LOBBY / STAFF				
	WORKING AREA.				
7.1.	UPS Points				
	THE POINTS FOR ESSENTIAL LOADS AND NON-ESSENTIAL LOADS SHOULD BE POWERED THROUGH				
	SEPARATE D.B.s AS MENTIONED BELOW. NO MIXING SHOULD BE DONE				
	All UPS Points (Essential OR Non-Essential to be erected from existing 8-Way & Existing 12-Way				
	<u>DB</u>				
7.1.a.	Non-Essential UPS Power points (From Existing 12 Way SPN DB)	No	6.00		



Phone: 020 - 25530622; Email: pecopne@canarabank.com; Website: www.canarabank.com

BOQ FOR ELECTRICAL WORKS IN BRANCH PREMISES & ATM LOBBY AT:

MEDICAL SQUARE BRANCH, DIST. NAGPUR						
S. NO.	DESCRIPTION OF ITEM	UNIT	QTY	RATE (₹) (Excl. GST)	AMOUNT (₹) (Excl. GST)	
Note	For Computer Points in Counters and Tables and for points for Printers etc., to be powered					
	through Branch UPS Output DB 2 (S.No. 2.e)					
	Supplying & Installing Primary UPS or Stabilized Power points on workstations / tables for					
	computers using using 2x2.5 Sq.mm. + 1x1.5 Sq. mm. PVC insulated multistanded FRLS Grade					
	flexible copper wires through 25mm size MMS Grade PVC conduites, laid on surface above false					
	ceiling and taken upto table top using 25/20 mm size MMS Grade PVC rigid or flexible conduits run					
	within wooden or metal partitions.					
	Each point consisting of 2 Nos of 6A, 5 Pin Modular sockets and 1 No. of 16A, 6 pin socket					
	controlled by 1 No 20A Modular switch & Indicator lamp, wired together forming one point. Earth					
	wire to be of Green colour only. Switch should be above table top & sockets with indicator should					
	be below table top.					
7.1.b.	Essential UPS Power points (From Existing 8 Way SPN DB)	No	4.00			
	For CCTV System, Fire Alarm System, Burglar Alarm System, Networking Rack, to be powered					
	through Branch UPS Output DB 1 (S.No. 2.d)					
Note	For ATM UPS Output, to be powered through ATM UPS Output DB (S.No. 2.g)					
	Supplying & Installing Primary UPS or Stabilized Power points on workstations / tables for					
	computers using using 2x2.5 Sq.mm. + 1x1.5 Sq. mm. PVC insulated multistanded FRLS Grade					
	flexible copper wires through 25mm size MMS Grade PVC conduites, laid on surface above false					
	ceiling and taken upto table top using 25/20 mm size MMS Grade PVC rigid or flexible conduits run					
	within wooden or metal partitions.					
	Each point consisting of 2 Nos of 6A, 5 Pin Modular sockets and 1 No. of 16A, 6 pin socket					
	controlled by 1 No 20A Modular switch & Indicator lamp, wired together forming one point. Earth					
	wire to be of Green colour only. Switch should be above table top & sockets with indicator should					
	be below table top.					
7.2.	RAW POWER POINTS					
	POINTS' QUANTITY TO BE KEPT STRICTLY AS MENTIONED BELOW					
7.2.a.	Primary Raw power points (To be drawn from RAW POWER & AC DB (S.No. 2.b))	No	3.00			
	for Printers / Cash counting machine / Water cooler etc.					
	Supplying & Installing Primary 20 A Power Socket points using 2x4.0 Sq.mm. + 1x2.5 Sq.mm. PVC					
	insulated multistanded FRLS Grade flexible copper wires (with proper color code) pulled through					
	heavy gauge PVC conduits directly from Power & AC DB.					
	Each point consisting of 1 Nos of 20 A Modular sockets controlled by 1 Nos of 20A Modular switch,					
	wired together forming a point. Earth wire to be of Green colour only.					
7 2 h	Secondary Raw power points (To be looped from Primary Raw Power Points (S.No.8.2.a.) - for	No	2.00			
, . L.D.	Counters & Tables & misc.	140	2.00			
	Supplying & Installing Primary 10/20 A Power Socket points using 2x2.5 Sq.mm. + 1x1.5 Sq.mm. PVC					
	insulated multistanded FRLS Grade flexible copper wires (with proper color code) pulled through					
	heavy gauge PVC conduits looped from Prima					
	Each point consisting of 1 Nos of 10/20 A Modular sockets controlled by 1 Nos of 20A Modular					
	switch, wired together forming a point. Earth wire to be of Green colour only.					
	Only 1 Secondary Raw power point must be looped from the Primary Power Point. A combination of					
	only 1 primary point & 1 secondary point to be served by one circuit taken from Raw Power & AC DB					

7.3. LIGHT POINT WIRING

Seal-Sign of the Bidder



BOQ FOR ELECTRICAL WORKS IN BRANCH PREMISES & ATM LOBBY AT	
--	--

	MEDICAL SQUARE BRANCH, DIST. NAGPUR				
S. NO.	DESCRIPTION OF ITEM	UNIT	QTY	RATE (₹) (Excl. GST)	AMOUNT (₹) (Excl. GST)
	SITC of following concealed point wiring using 1100V grade 3x1.5 Sq. mm. Multistrand copper				
	conductor PVC insulated FRLS wires (with proper R,Y,B colour code) pulled through 25mm / 20mm				
	Size, MMS Grade PVC conduits. All wiring below false ceiling shall be concealed. The wires from				
	ceiling junction to light points shall be drawn in flexible PVC conduit with adaptor & cover for				
	junction box & crimp type lugs at both ends. Each circuit feeding not more than average 12 points				
	(800 watts). The rate shall include circuit wiring (2x2.5 Sq. mm. + 1x1.5 sq.mm.) from Lighting DB to				
	switchboard and to the fixtures. (No seperate measurements for circuit wiring & PVC				
	Conduits)The First Point will be considered as Primary Point and balance points as Secondary				
	Points.				
7.3	The existing Light points should be re-utilised first then new light points to be provided	N1.	45.00		
/.3.a.	Primary Light points, Powered from LIGHTING DB (S.No. 2.a)	No	45.00		
	SITC 5/6A Primary light points including MS concealed box, grid plate, 6A switch & circuit wiring				
7 2 6	through LDBs	N-	20.00		
7.3.D.	Primary Light points, Powered from INVERTER Lighting DB (S.No. 2.f)	No	20.00		
	SITC 5/6A Primary light points including MS concealed box, grid plate, 6A switch & circuit wiring				
736	through Inverter DB Secondary Light points, to be looped from Primary Light Points (S. No. 7.3.a.)	No	20.00		
7.3.0.	SITC 5/6A Secondary light points looped from primary light point.	NO	20.00		
7 3 d	Independent 5/6A socket points, Powered from LIGHTING DB (S.No. 2.a)	No	3.00		
7.5.u.	SITC of Primary 5/6A Socket points using circuit wiring (with proper color code) pulled through	140	3.00		
	medium gauge PVC conduits.				
	Each point consisting of 1 Nos 5 pin of 5/6A sockets controlled by 1 Nos of 6A switch, wired				
	together forming a point with Green colour Earth wire.				
7.3.e.	Dependent 5/6 A socket points (on Board plug points), Powered from LIGHTING DB (S.No. 2.a)	No	10.00		
7,0,0	population of the police points (on police principle), the principle is the police pol	.,.	10,00		
	SITC Secondary 5/6A Socket points using circuit wiring (with proper color code) pulled through				
	haevy gauge PVC conduits. These points are installed on the Lighting Switch Board.				
	Each point consisting of 1 Nos of 5 pin 5/6A sockets controlled by 1 Nos of 6A switch, wired				
	together forming a point. Earth wire to be of Green colour only.				
7.3.f.	Exhaust fan points, Powered from LIGHTING DB (S.No. 2.a)	No	4.00		
	SITC of concealed point wiring for Exhaust fan using 1100V grade 3x1.5 Sq. mm. Multistrand Copper				
	Conductor PVC insulated FRLS wires (with proper R,Y,B colour code) pulled through 25mm / 20mm				
	Size, MMS Grade PVC conduits. All wiring below false ceiling shall be concealed. The wires from				
	ceiling junction to fan points shall be drawn in flexible PVC conduit with adaptor & cover for junction				
	box & crimp type lugs at both ends.				
	The rate shall include circuit wiring (2x2.5 Sq. mm. + 1x1.0 Sq. mm.) from Lighting DB to				
	switchboard and to the Exhaust fan and Wall fan. (No seperate measurements for circuit wiring &				
	PVC Conduits)				
	Each Exhaust Fan will be operated on seperate switch, Rate should be including the cost of 6 A				
73~	switch, 4 way closed 5A connector & Mounting Plates & Ceiling Rose.	NI.	F 00		
7.3.g.	Wall Fan points, Powered from INVERTER Lighting DB (S.No. 2.f)	No	5.00		
	SITC of concealed point wiring for Exhaust fan using 1100V grade 3x1.5 Sq. mm. Multistrand Copper				
	Conductor PVC insulated FRLS wires (with proper R,Y,B colour code) pulled through 25mm / 20mm				
	Size, MMS Grade PVC conduits. All wiring below false ceiling shall be concealed. The wires from				
	ceiling junction to fan points shall be drawn in flexible PVC conduit with adaptor & cover for junction				
	box & crimp type lugs at both ends. The rate shall include circuit wiring (2x2.5 Sq. mm. + 1x1.0 Sq. mm.) from Lighting DB to				
	switchboard and to the Exhaust fan and Wall fan. (No seperate measurements for circuit wiring & PVC Conduits)				
	Each wall fan will be operated on seperate switch, Rate should be including the cost of 5/6 A switch,				
	3 pin 5/6A socket, gang box & Mounting Plates				
736	Ceiling fan points, Powered from LIGHTING DB (S.No. 2.a)	No	4.00		
1.3.11.	Centing fair points, rowered from Light ind DD (5.110. L.a)	140	7.00		



	MEDICAL SQUARE BRANCH, DIST. NAGPUR					
S. NO.	DESCRIPTION OF ITEM	UNIT	QTY	RATE (₹) (Excl. GST)	AMOUNT (₹) (Excl. GST)	
	SITC Ceiling Fan point operated on seperate switch shall be Controlled by 2 Module, 5-Step Fan					
	regulator, Rate should be including the cost of Fan hook, Suspending suitable fan rod, Connecting					
	cord and Step type Fan Regulator					
7.3.i.	Re-utilising existing Light Points by re-routing the light point to the nearest fixture	No	20.00			
8.1.	Indicator Lights point (for Non-Essential VTPN DB1)	Set	1.00			
	Providing and fixing R-Y-B Indicator LED Light Assembly concealed in display boxing along with Point					
	Wiring to be done with 4C 1.5 Sq.mm. PVC insulated multistanded FRLS Grade flexible copper Cable					
	drawn through Heavy gauge PVC conduit from Respective DB / MCCB. The route of the indicator					
	wiring to be as under:					
	4C 1.5 Sq.mm. cable looped from Output side of MCCB of Main Panel VTPN DB1 (1.3.1 (ii))					
	<u>TO</u>					
	R-Y-B Indicator Lamp Near Entrance					
	R-Y-B Colour Indicator Lamps for Non-Essential Power VTPN DB					
	The indicators must be placed next to the main entrance at a suitable location so that they are visible					
	through any one of the branch's CCTV Cameras The looping of the cable must be done carefully using proper lugs and must be fastened rigidly to avoid					
	faults					
	lauits					
2 2	Indicator Lights point (for Non-Essential UPS Output Load & Inverter Lighting Load)	Set	2.00			
6.2.	Providing and fixing Single Indicator LED Light of mentioned colour concealed in display boxing along	361	2.00			
	with Point Wiring to be done with 2C 1.5 Sq.mm. PVC insulated multistanded FRLS Grade flexible					
	copper Cable drawn through Heavy gauge PVC conduit from Respective DB / MCCB. The route of the					
	indicator wiring to be as under:					
	1. 2C 1.5 Sq.mm. cable looped from Output side of DPMCB1 of MB Box near branch entrance (3.a					
	(ii)) to R-Led Indicator					
	2. 2C 1.5 Sq.mm. cable looped from Output side of DPMCB2 of MB Box near branch entrance (3.a					
	(ii)) to B-Led Indicator					
	R-Indicator LED Light Assembly concealed in display boxing for Non Essential Branch UPS Output					
	B-Indicator LED Light Assembly concealed in display boxing for Inverter Lighting Output					
	Red Colour Indicator lamp for Non-Essential UPS Output					
	Blue Colour Indicator lamp for Inverter Lighting Output					
	The indicators must be placed next to the main entrance at a suitable location so that they are visible					
	through any one of the branch's CCTV Cameras					
	The looping of the cable must be done carefully using proper lugs and must be fastened rigidly to avoid					
	faults					
	EARTHING SYSTEM					
9.1.	Plate Earthing					
	S & I of Earthing Pit / Earth Electrode Station into the true ground level by using GI / Copper Plate					
	type earthing with necessary excavation in soft soil, including Pouring Charcoal & Salt (
	Approximately) 50kg each per Pit with Predrilled 50mm dia B class GI Pipe-2.5 Mtr In length, GI					
	Funnel with wiremesh, 35 x 5mm GI/Cu Earthing Strip, Complete job with necessary construction of					
	appropriate sized Earthing PIT masonary Chamber with providing CI hinged chamber cover, Nutbolts,					
	Earthing Testing Link, Hardware, Numbering of Chamber by using water proof paint. For more					
	details refer IS 3043-1987 Brazing for Cu & Welding for GI Plate to pipe & Strip shall be done with					
	coating by anti-corrosive paint					
9.1.a.	CU Plate earthing.	No	2.00	•		
	Copper earthing pit made up of $600 \times 600 \times 3$ mm thick, copper electrode including 25×5 mm					
	Copper strip.					
9.2.	Earthing Wires					



	MEDICAL SQUARE BRANCH, DIST. NAGPUR				
S. NO.	DESCRIPTION OF ITEM	UNIT	QTY	RATE (₹) (Excl. GST)	AMOUNT (₹) (Excl. GST)
	SITC of insulated copper earthing wire laid through 20 mm PVC conduits from separately made earth pit to the equipment in following sizes			,	, ,
9.2.a.	Single core, 4 sqmm FRLS PVC insulated multi threaded, flexible copper wire laid through 20 mm size, MMS Grade PVC Conduites for Raw Power Earthing.	Rmt	80.00		
9.2.b.	Single core, 6 sqmm FRLS PVC insulated multi threaded, flexible copper wire laid through 20 mm	Rmt	80.00		
	size, MMS Grade PVC Conduites for UPS power Earthing.				
9.3.	Main Earth Bus	No	2.00		
	Supplying & Installing of Main bus for isolated earth comprising of 200mm x 40mm x 6mm thick copper bar fixed on insulated support and having 20 nos of holes and nut bolts studs for clamping the earth leads, all contained in MS/PVCbox of size 300mm x 200mm x 50mm deep and having transparent acrilic inspection cover as approved by Bank / Architect.				
10	TELEPHONE / VOICE CABLING AND OUTLETS	No	2.00		
	Providing and laying 2 Pair Grey Color 0.5mm Tinned Cu , PVC insulated cable for Telephone / Voice, laid through 20 / 25 mm size, MMS Grade PVC Conduites and Supplying & terminating with RJ-11 Telephone Jack / Outlet with face plates in suitable modular PVC / MS box from EPABX / Krone Tag Box to the work stations and terminate the other on a 10 pair Krone module installed in a Krone Tag box, complete 10-pair 0.5 Sq. mm. size Telephone Cable for incoming with numbering of each cable with Ferule and Telephone Connection Chart (No seperate measurements for PVC Conduits)				
	DATA CABLING SYSTEM				
	Data points	No	7.00		
	Supplying and laying D-Link / Molex / Awaya / Amps make, Cat 6 cable for Data, laid through 20/25 mm size, MMS Grade PVC conduites and providing & terminating with RJ-45 Information Outlet Ports with face plates in suitable modular PVC / MS box from Server Rack/ Patch Panel/ Data Switch to individual work stations & terminating other end with RJ-45 connector including numbering with ferule (No seperate measurements for PVC Conduits)				
11.2.	Supplying & laying Cat-6, RJ-45, 1 m. length Data Patch Cords,	No	7.00		
	Make : D-Link / Molex / Awaya				
11.3.	Supplying & laying Cat-6, RJ-45, 2 met length Data Patch Cords, Make: D-Link / Molex / Awaya	No	7.00		
	WIGGELL AND OUR WORKS				
	MISCELLANEOUS WORKS Supply and installation of Vinyl sticker for on Electrical DBs like, " <u>Switch Off at Night", Switch Off</u> For Safety, etc	Nos.	4.00		
12.2.	Angle holder complete in all respect with 9W White LED Bulb	Nos.	5.00		
	SITC of LED COVE / STRIP LIGHT WITH ITS ELECTRONIC DRIVER (BLUE COLOUR): Supply, installation, testing and commissioning of bright LED strip light with its electronic driver complete as required. (Make: PHILIPS, WIPRO, HAVELLS, CG).	Mtrs	50.00		
12.4.	Supply and laying of ISI mark Electrical safety Insulating mat of dimension 1000mm X 1000mm in Electrical panel & UPS Room.	Nos.	2.00		
	Supply and fixing 300 X 50 mm MS Perforated Cable Tray for laying for wires and cables above False Ceiling using MS fastners & suspenders bolted rigidly to ceiling and walls. Tee joints to be used wherever necessary for providing path for cables wires etc.	R. Mtr.	50.00		
	Dismantling and Refixing in position the following items: 20W LED 4' Baten fitting Rainforced plastic body, milky difusser	Nos.	30.00		
a	LOW LED 4 Daten fitting naminorced plastic body, inflitty diffusion	1402.	30.00		
13	FIXTURES				



Phone: 020 - 25530622; Email: pecopne@canarabank.com; Website: www.canarabank.com

BOQ FOR ELECTRICAL WORKS IN BRANCH PREMISES & ATM LOBBY AT:								
MEDICAL SQUARE BRANCH, DIST. NAGPUR								
S.	DESCRIPTION OF ITEM	UNIT	QTY	RATE (₹)	AMOUNT (₹)			
NO.				(Excl. GST)	(Excl. GST)			
	SITC of following concealed / surface mounted fixtures of makes as specified with all fixture							
	accessories like suitable tubes/ bulbs/ ballast & internal wiring etc. The contractor has to assemble							
	& install the said fixtures at position with necessary hardware required for installation like S-hook,							
	chain link etc. as per requirement.							
13.1.	10W Down lighter with LED	No	35.00					
	SITC 10W White Powder Coated Housing LED Round / Square Down Lighter with High Efficiency							
	LEDs & Ballasts							
13.2.	600 x 600 mm square LED panel fittings	No	25.00					
	SITC of Full Glow 36W / 40W White LED Square Light Panel of 600mm X 600mm size, Powder coated							
	Recess mounting LED Light Fitting (Min 6000K)							
13.3.	Fans							
	Supplying & Installing following mentioned Aluminum, medium duty, powder coated with glossy color							
	Ceiling Fans / Wall Fans / Exhaust Fans with necessary clamps hook, bracket, hardware etc							
13.3.a.	SITC 1200 mm sweep Ceiling fans Complete with Mounting rod, Clamps, Locking pin etc. (Color -	No	4.00					
	White / Ivory / Brown)							
13.3.d.	SITC 400mm sweep Wall fan of 1350 RPM. Oscillating type, Metal Body & blades chrome plated guard	No	6.00					
	with speed regulator and moisture proof treatment to winding and with 'E' class insulation.							
	TOTAL FOR ELECTRICAL WORKS							

CGST 9%
SGST 9%
GRAND TOTAL