

PREMISES & ESTATE SECTION
CANARA BANK, 2ND FLOOR, B WING,
BKC, CIRCLE OFFICE, BANDRA (E), MUMBAI
LL No.-022-26728463/8465; email-emcomcity@canarabank.com

REF. NO :: MCEM/OP-051/ON-393/599/AS/2018

Date: 22.06.2018

Minutes of the pre-bid meeting held on 12/06/2018 for Supply, Installation, Testing and Commissioning of 1 number of 6-passenger capacity lift by dismantling the existing passenger lift, at Canara Bank residential building- '4D Pancharatna Building', Damodar Park, Ghatkopar West, Mumbai-86.

TENDER REF: 09/MECM/2018 DATED 05.06.2018.

MEMBERS PRESENT FROM BANK:

- | | |
|-----------------------------|---------------------------|
| 1. Shri Ashish Singh | : Technical Field Officer |
| 2. Shri Surya Pratap Mishra | : Officer |

BIDDER'S REPRESENTATIVE PRESENT FROM:

1. M/s Jolly Elevators Pvt. Ltd.
2. M/s Escon Elevators Pvt. Ltd.
3. M/s Johnson Lifts Pvt. Ltd.
4. M/s Victora Lifts Pvt. Ltd.
5. M/s Jet Elevators


The Clarifications for the queries raised by the bidders and Corrigendum to certain clauses in tenders are enclosed herewith.

This Corrigendum shall form part of and shall be read with Tender / contract documents and shall become part of the contract and shall be signed on every page and enclosed with the bid.

In case of any discrepancy between this corrigendum and other tender / contract documents, the former shall prevail.

All the tender terms & conditions other than those modified in this corrigendum remain unchanged.

Yours Faithfully,


HEMANT TASKHEDKAR
DIVISIONAL MANAGER



TENDER REF. NO. 09/MCEM/2018 DATED 05/06/2018
 Supply, Installation, Testing and Commissioning of 1 number of 6-passenger capacity lift by dismantling the existing passenger lift, at Canara Bank residential building- "4D, Pancharatra Building", Damodar Park, Ghatkopar West, Mumbai-86

CORRIGENDUM TO TENDER DOCUMENT

S.NO.	Page No.	CLAUSE No.	QUERIES IN BRIEF	REPLY TO QUERIES AND CLARIFICATIONS
1	1	Clause No. 01- Work	NBC norms regarding mandatory requirement of 1 No. of Fire lift. (8 passenger capacity)	The shaft size is not adequate to provide a fire lift of 8 passenger capacity. Hence, 6 passenger capacity lift needs to be provided. Permission from Chief Fire Officer for commissioning of 6 passenger capacity lift needs to be obtained by the supplier before commencement of the work.
2	1	Clause No. 03- Time of completion	Clarification regarding time of completion	Time of completion will be 6 months from the date of approval of GAD.
3	17	Clause No. 6- Permits and Licenses	Clarification regarding obtaining of Permits and Licenses	The clause may be read as follows- 6.1 Permits and licenses for the release of materials or its purchases which are under Government control will be arranged by the contractor. It may be clearly understood that no compensation or additional charges can be claimed by the contractor for non-availability of such materials in due time on this account or according to his own requirements. 6.2 The contractor may, however, be eligible to a proportionate extension of time on this account which in the opinion of the Employer / Consultant is reasonable.
4	27	Clause No. 30- Payment Terms	Clarification regarding payment terms	Remains unchanged.
5	40	Clause No. 1.5 of Special Instructions to the Tenderer	Special instruction to the tenderer regarding obtaining of lift license and other statutory permissions	Lift license and/ or other statutory permits shall be obtained by the Contractor. The charges for the same shall be reimbursed by the bank on furnishing of receipt. The successful tenderer shall obtain the necessary permission for commencement of work from the statutory authority during initial stages and after completion of the work. All the required documents have to be arranged by the tenderer and Bank will be able to produce the documents such as architect's certificate and RCC certificate from structural consultant.
6	47 & 48	Clause No. 2.2.28- List of approved makes	Clarification regarding Make of motor, cables and VVVF controls	Equivalent reputed make means price and rating should match.
7	49	Clause No. C- Inspection and Testing	Clarification regarding inspection and testing	Remains unchanged.
8	51	Clause No. D (v) Design Criteria of Technical Specifications	Speed	Speed of lift will be 1.00 m/s instead of 1.25 m/s.
9	--	--	Clarification regarding waterproofing of lift pit	Lift pit waterproofing will be in Bank's scope.
10	--	--	Clarification regarding structural stability certificate	RCC certificate/ structural stability certificate will be arranged by the Bank.

Ashish Singh
TFO

Mahesh J Kholgade
MANAGER

Hemant Taktekar
DIVISIONAL MANAGER