








NOTE:
1.STRUCTURE TO BE CONSTRUCTED IN ACCORDANCE WITH I.S.456-2000 & N.B.C. OF INDIA (SP-7-1983)
2.STRUCTURAL ENGINEER RESPONSIBILITY IS LIMITED TO DESIGN & ISSUAL OF STRUCTURAL DRAWING ONLY.
3.FOR SEISMIC LOADS NOMINAL PROVISIONS ONLY CONSIDERED IN THE DRG.
4.ONUS OF CONSTRUCTION LIES WITH CONTRACTOR / PROMOTER / BUILDER/ OWNER.

NOTES:
1.ALL DIMENSIONS ARE IN MM AND METRE
2.CONCRETE GRADE M25 (1:1:2)
3.STEEL GRADE: Φ Fe 500
4.CLEAR COVER FOR COLUMN=40 FOOTING=50 PLINTH=25
5.LAP LENGTH FOR COLUMN = 50 X DIA OF BAR AND BEAM & SLAB = 60 X DIA OF BAR.
6.REINFORCEMENT TO BE CHECKED AND APPROVED BY STRUCTURAL ENGINEER (FOR SAFETY PRECAUTION)
7.STRUCTURE DESIGNED FOR GROUND FLOOR

**PROPOSED DG SET STRUCTURE
BASE FOR CANARA BANK
REGIONAL OFFICE @
ANNA SALAI, TEYNAMPET
CHENNAI**

**FOOTING COLUMN
PLINTH LAYOUT & R.C. DETAILS**

CLIENT:
ENERGY MULTIPLES
TEYNAMPET
Chennai

DRAWN: J.B. **DATE =** 12-04-21






CHECKED: G.K.

STRUCTURAL CONSULTANT:
G.KARTHIKEYAN M.E., MBA.,
G.K.STRUCTURALS

3H, 3rd Floor,
VANTAGE PLAZA,
#1, L.B. & M.G. Road,
Thiruvannmiyur,Chennai-41.

MOBILE: 94440-46245
E-MAIL : gkstructural@hotmail.com

DRG:NO. ME02-12/04/21



FOOTINGS SCHEDULE:

FOOTING NO	FOOTING SIZE "mm"			REINFORCEMENT DETAILS	
	L	B	D	SHORTER DIRECTION X - DIRECTION	LONGER DIRECTION Y - DIRECTION
F1	1200	1200	300	10Y@150C/C	10Y@150C/C