

PREMISES & ESTATE SECTION
CANARA BANK, 2ND FLOOR, B WING,
BKC, CIRCLE OFFICE, BANDRA (E), MUMBAI
PH. NO.- 022-26728463/8465; email-emcomcity@canarabank.com

Date: 07/07/2021

MINUTES OF PRE-BID MEETING HELD ON 29.06.2021 FOR OPERATION OF CENTRALIZED AIR-CONDITIONING PLANT AND COMPREHENSIVE MAINTENANCE OF THE LOW SIDE EQUIPMENT IN BANK'S BUILDING AT BANDRA-KURLA COMPLEX, MUMBAI

Members present from Bank:

1. Mr. Vidhresh Kumar- Manager, Premises & Estate Section, Circle Office
2. Mr. Ashish Singh- Manager, Premises & Estate Section, Circle Office

Bidder's representatives present from:



1. M/s Associated Engineers
2. M/s Ace Global Aircon Services Ltd.
3. M/s Airtek HVAC LLP
4. M/s ATS Aircon
5. M/s Aqua Cool Co. Pvt. Ltd.
6. M/s Speedfrost Services Pvt. Ltd.
7. M/s Sterling & Wilson Pvt. Ltd.
8. M/s Toot MNE Tech Pvt. Ltd.

The clarifications for the queries raised by the bidders and Corrigendum to certain clauses in the tender are enclosed herewith.

This Corrigendum shall form a part of and shall be read with tender/ contract documents and shall become part of the contract and shall be signed on every page and shall be enclosed with the bid.

In case of any discrepancy between this Corrigendum and other tender/ contract documents, the former shall prevail.


All the tender terms and conditions other than those modified in this Corrigendum remain unchanged.


MAJ. G.N. TIWARI
DIVISIONAL MANAGER




TENDER REF. NO. 03/MCPE/2021 DATED 18/06/2021					
OPERATION OF CENTRALIZED AIR-CONDITIONING PLANT AND COMPREHENSIVE MAINTENANCE OF THE LOW SIDE EQUIPMENT IN BANK'S BUILDING AT BANDRA-KURLA COMPLEX, MUMBAI					
CLARIFICATIONS FOR THE QUERIES AND CORRIGENDUM TO TENDER DOCUMENT					
Sr. No.	Page No.	Clause No.	Queries in brief	Bank's reply to queries	Amendments in the tender, BOQ
1	4	Description and Eligibility Criteria	Details of floor-wise and wing-wise capacities of Air Handling Units	The details are provided in ANNEXURE-1	No amendments in the tender, BOQ.
2	71	Pt. No. D of Annexure-2 of Price bid	Specification of Actuators	The actuator assembly to be installed shall mate and match with the existing pipeline, complete in all respects.	No amendments in the tender, BOQ.


 ASHISH SINGH
 MANAGER (TECH)


 VIDHNESH KUMAR
 MANAGER (TECH)


 MAJ. G. N. TIWARI
 DIVISIONAL MANAGER



Annexure 1

Air Handling Unit (AHU) details for centralized air conditioning plant			
Sr. No.	Floor	Wing	Flow (in CFM)
1	Ground	Lift Lobby	5000
2	Ground	Lift Lobby	2500
3	Ground	A	11000
4	Ground	B	10000
5	1 st	Lift Lobby	5000
6	1 st	A	15000
7	1 st	B	10000
8	2 nd	Lift Lobby	5000
9	2 nd	A	10000
10	2 nd	B	10000
11	3 rd	A auditorium	9000
12	3 rd	B auditorium	9000
13	3 rd	Lift Lobby	5000
14	3 rd	A	10000
15	3 rd	B	10000
16	4 th	Lift Lobby	5000
17	4 th	A	10000
18	4 th	B	10000
19	5 th	Lift Lobby	5000
20	5 th	A	12000
21	5 th	B	10000
22	6 th	Lift Lobby	5000
23	6 th	A	11000
24	6 th	B	10000
25	7 th	Lift Lobby	5000
26	7 th	A	10000
27	7 th	B	10000
28	8 th	Lift Lobby	5000
29	8 th	A	12000
30	8 th	B	10000
31	9 th	A	5000
32	9 th	B	13000
33	9 th	Canteen	5000
34	9 th	Canteen	6000
		TOTAL	285500

