

**SUB : EXTERNAL CIVIL WORKS AND INTERNAL RENOVATION OF 56 FLATS AT BANK OWNED STAFF QUARTERS BUILDING AT SAHAYADRI APARTMENTS, MYSORE ROAD, BANGALORE - ISSUE OF AMENDMENT/CLARIFICATIONS.**

REF : RFP/007/2021 dated 20.09.2021

The pre-bid meeting was held at the site at the scheduled date on 28.09.2021 @ 3:00PM. Four of the prospective bidders attended the meeting. The copy of the pre-bid meeting register is enclosed. There were no written queries submitted to the Bank. Following points emerged during the meeting for which clarification/corrigendum is given as under :

SL	TENDER REFERENCE	CLARIFICATION/ADDENDUM
1	Tender Document -> Conditions of Contract -> Clause-10A, Page 25 - Materials to be provided by the bidder, tests	<p>Addition of Subhead</p> <p>vi. The bidder shall carryout the tests specified as per the relevant Indian Standards/ Specifications in IISc Bangalore, Government Engineering College laboratories or other NABL accredited laboratories in Bangalore and submit to the Bank Engineer the test results in triplicate within 3 (three) days after completion of the test.</p> <p>vii. The bidder shall take the representative samples of each consignment of materials brought to the site as per the sampling criteria stipulated as per IS Codes, CPWD Works Manual in presence of the Bank engineer.</p> <p>The acceptance criteria of the samples tested shall be in accordance with the requirements of the relevant Indian Standards/CPWD Works manual.</p>
2	Tender Document -> General Rules and Directions to Tenderers -> Clause-24, Page 12 - Integrity Pact	The hard copy of the signed integrity pact as per prescribed format to be submitted to the address of the issuing authority before the date of tender opening date/time.
3	Financial Bid -> External Works -> Item Ref : A.V.4 - Masonry Chamber with covers	The quantity should be read as 14 Nos instead of 6000 Nos
4	Financial Bid -> Internal Renovation Works -> Item Ref : B.III.1 - Waterproofing of toilets	"Brick bat coba" to be read as "Brick bat coba or any other filler material"



5	Financial Bid -> Internal Renovation Works -> Item Ref : B.III.2 - Re-filling brick bat coba	"Brick bat coba" to be read as "Brick bat coba or any other filler material"
6	Financial Bid -> Internal Renovation Works -> Sanitary Fittings	The model numbers approved by Bank for the following items under the subhead are mentioned below :
	B.VII.1 - European Type Water Closet Pan + Flushing Cistern	Jaquar Essco Model No : ECS-WHT-551SN or equivalent of other approved makes
	B.VII.2 - Wash Basin-Surgeon Type	Jaquar Essco Model No : ECS-WHT-933 or equivalent of other approved makes
	B.VII.3 - SS Kitchen Sink	Nirali Elegance Ultra or equivalent of other approved makes
	B.VII.6 - Swan Neck sink cock	Jaquar Essco Model No : APR-101347N or equivalent of other approved makes
	B.VII.7 - Pillar cock	Jaquar Essco - Model No : APR-101001M or equivalent of other approved makes
	B.VII.8 - Wall Mixer	Jaquar Essco Model No : TQT-517B or equivalent of other approved makes
	B.VII.9 - 2 way bib cock with health faucet	Jaquar Essco Model No : APR-101041 or equivalent of other approved makes Jaquar Essco Model No : ALE-BLK-583 or equivalent of other approved makes
	B.VII.10 - Shower head	Jaquar Essco Model No : EOS-542A or equivalent of other approved makes

**REVISED SOQ/FINANCIAL BID IS ENCLOSED. BIDDERS ARE TO QUOTE AS PER THE REVISED FORMAT ONLY.**

The above clarifications/addendums will be treated as part of the tender and there are no other changes in the terms and conditions.

